



Appendix E Stationary Source Modelling Data

Environmental Noise & Vibration Assessment

130 Mountainview Road North, Georgetown

Whitestone (Georgetown Developments) General Partnership

SLR Project No.: 241.031484.00001

December 6, 2024

STATIONARY SOURCE MODELLING DATA

Source Description	Maximum Sound Power Level (1/1 Octave Bands) (dB)										Modelled Sound Power Level (dBA)	Source Notes
	31.5	63	125	250	500	1000	2000	4000	8000			
Communications & Power Industries Canada Inc												
Rooftop HVAC - 5 ton	77	80	81	81	80	78	74	70	64	83		Based on historical SLR data Operating 60/45/15 minutes per daytime/evening/nighttime hour
Rooftop HVAC - 10 ton	80	83	84	84	83	81	77	73	67	86		Based on historical SLR data Operating 60/45/15 minutes per daytime/evening/nighttime hour
Generic MUA - Inlet	-	78	79	73	75	69	63	56	45	75		Based on historical SLR data Operating continuously during daytime, evening, nighttime hours
Generic MUA - Casing	-	72	79	69	67	60	48	34	25	68		Based on historical SLR data Operating continuously during daytime, evening, nighttime hours
Generic Mechanical Intake/Exhaust Plenum (Ground Level)	-	82	81	81	81	76	71	66	58	82		Based on historical SLR data Operating continuously during daytime hours
Kitchen Exhaust Fan	-	78	88	83	77	72	70	64	61	80		Based on historical SLR data Operating continuously during daytime hours
Upblast Mushroom Exhaust Fan	-	-	80	76	79	71	67	64	59	79		Based on historical SLR data Operating continuously during daytime, evening, nighttime hours
Generic Exhaust Stack/Fan - Small	-	83	93	88	82	77	75	69	66	85		Based on historical SLR data Operating continuously during daytime hours
Generic Exhaust Stack/Fan - Medium (incl. Paint Booth Exhausts)	-	99	99	92	88	82	78	72	66	90		Based on historical SLR data Operating continuously during daytime hours
Air Cooled Condenser - 2 fan	-	93	99	93	89	85	80	74	65	91		Based on historical SLR data Operating continuously during daytime hours
Air Cooled Condenser - 4 fan	-	94	100	94	91	86	81	75	66	92		Based on historical SLR data Operating continuously during daytime hours
Georgetown GO Layover Yard												
Idling Train (each)	117	127	114	110	103	98	97	95	90	108		Based on historical SLR data Each train idles 15 min/hour during daytime, evening, nighttime hours



Content Copy Of Original



Ministry of the Environment and Climate Change
Ministère de l'Environnement et de l'Action en matière de changement
climatique

ENVIRONMENTAL COMPLIANCE APPROVAL

NUMBER 8860-ADKLHS

Issue Date: September 29, 2016

Communications & Power Industries Canada Inc.
45 River Drive
Georgetown, Ontario
L7G 2J4

Site Location: 45 River Drive
45 River Dr
Halton Hills Town, Regional Municipality of Halton
L7G 2J4

You have applied under section 20.2 of Part II.1 of the Environmental Protection Act, R.S.O. 1990, c. E. 19 (Environmental Protection Act) for approval of:

Description Section

A communication and electronic medical equipment manufacturing facility, consisting of the following processes and support units:

- electroplating;

- coating;
- potting;
- degreasing;
- soldering and brazing;
- laboratory operations;
- painting and drying;
- sandblasting;
- welding and general maintenance activities; and
- product assembly.

including the *Equipment* and any other ancillary and support processes and activities, operating at a *Facility Production Limit* of up to 60 units per shift per day discharging to the air as described in the *Original ESDM Report*.

For the purpose of this environmental compliance approval, the following definitions apply:

1. " *Acceptable Point of Impingement Concentration*" means a concentration accepted by the *Ministry* as not likely to cause an adverse effect for a *Compound of Concern* that,

(a) has no *Ministry Point of Impingement Limit* and no *Jurisdictional Screening Level*, or

(b) has a concentration at a *Point of Impingement* that exceeds the *Jurisdictional Screening Level*.

With respect to the *Original ESDM Report*, the *Acceptable Point of Impingement Concentration* for a

- Compound of Concern* mentioned above is the concentration set out in the *Original ESDM Report*.
2. "*Acoustic Assessment Report*" means the report, prepared in accordance with *Publication NPC-233* and Appendix A of the *Basic Comprehensive User Guide*, by John Coulter, P.Eng. / J.E. Coulter Associates Limited and dated September 8, 2011, submitted in support of the application, that documents all sources of noise emissions and *Noise Control Measures* present at the *Facility*, as updated in accordance with Condition 5 of this *Approval*.
 3. "*Acoustic Assessment Summary Table*" means a table prepared in accordance with the *Basic Comprehensive User Guide* summarising the results of the *Acoustic Assessment Report*, as updated in accordance with Condition 5 of this *Approval*.
 4. "*Acoustic Audit*" means an investigative procedure consisting of measurements and/or acoustic modelling of all sources of noise emissions due to the operation of the *Facility*, assessed to determine compliance with the Performance Limits for the *Facility* regarding noise emissions, completed in accordance with the procedures set in *Publication NPC-103* and reported in accordance with *Publication NPC-233*.
 5. "*Acoustic Audit Report*" means a report presenting the results of an *Acoustic Audit*, prepared in accordance with *Publication NPC-233*.
 6. "*Acoustical Consultant*" means a person currently active in the field of environmental acoustics and noise/vibration control, who is familiar with *Ministry* noise guidelines and procedures and has a combination of formal university education, training and experience necessary to assess noise emissions from a *Facility*.
 7. "*Approval*" means this entire Environmental Compliance Approval and any *Schedules* to it.
 8. "*Basic Comprehensive User Guide*" means the *Ministry* document titled "Basic Comprehensive Certificates of Approval (Air) User Guide" dated March 2011, as amended.
 9. "*Company*" means Communications & Power Industries Canada Inc. that is responsible for the construction or operation of the *Facility* and includes any successors and assigns in accordance with section 19 of the *EPA*.
 10. "*Compound of Concern*" means a contaminant described in paragraph 4 subsection 26 (1) of *O. Reg. 419/05*, namely, a contaminant that is discharged from the *Facility* in an amount that is not negligible.
 11. "*Description Section*" means the section on page one of this *Approval* describing the *Company's* operations and the *Equipment* located at the *Facility* and specifying the *Facility Production Limit* for the *Facility*.
 12. "*Director*" means a person appointed for the purpose of section 20.3 of the *EPA* by the *Minister* pursuant to section 5 of the *EPA*.
 13. "*District Manager*" means the District Manager of the appropriate local district office of the *Ministry*, where the *Facility* is geographically located.
 14. "*Emission Summary Table*" means a table described in paragraph 14 of subsection 26 (1) of *O. Reg. 419/05*; namely a table in the *ESDM Report* that compares the *Point of Impingement* concentration for each *Compound of Concern* to the corresponding *Ministry Point of Impingement Limit*, *Acceptable Point of Impingement Concentration*, or *Jurisdictional Screening Level*.
 15. "*Environmental Assessment Act*" means the Environmental Assessment Act, R.S.O. 1990, c.E.18, as amended.
 16. "*EPA*" means the Environmental Protection Act, R.S.O. 1990, c.E.19, as amended.

17. "*Equipment*" means equipment or processes described in the *ESDM Report*, this *Approval* and in the *Schedules* referred to herein and any other equipment or processes.
18. "*Equipment with Specific Operational Limits*" means any *Equipment* related to the thermal oxidation of waste or waste derived fuels, fume incinerators or any other *Equipment* that is specifically referenced in any published *Ministry* document that outlines specific operational guidance that must be considered by the *Director* in issuing an *Approval*.
19. "*ESDM Report*" means the most current Emission Summary and Dispersion Modelling Report that describes the *Facility*. The *ESDM Report* is based on the *Original ESDM Report* and is updated after the issuance of this *Approval* in accordance with section 26 of *O. Reg. 419/05* and the *Procedure Document*.
20. "*Facility*" means the entire operation located on the property where the *Equipment* is located.
21. "*Facility Production Limit*" means the production limit placed by the *Director* on the main product(s) or raw materials used by the *Facility*.
22. "*Independent Acoustical Consultant*" means an *Acoustical Consultant* who is not representing the *Company* and was not involved in preparing the *Acoustic Assessment Report* or the design/implementation of *Noise Control Measures* for the *Facility* and/or *Equipment*. The *Independent Acoustical Consultant* shall not be retained by the *Acoustical Consultant* involved in the noise impact assessment or the design/implementation of *Noise Control Measures* for the *Facility* and/or *Equipment*.
23. "*Jurisdictional Screening Level*" means a screening level for a *Compound of Concern* that is listed in the *Ministry* publication titled "Jurisdictional Screening Level (JSL) List, A Screening Tool for Ontario Regulation 419: Air Pollution - Local Air Quality", dated February 2008, as amended.
24. "*Log*" means a document that contains a record of each change that is required to be made to the *ESDM Report* and *Acoustic Assessment Report*, including the date on which the change occurred. For example, a record would have to be made of a more accurate emission rate for a source of contaminant, more accurate meteorological data, a more accurate value of a parameter that is related to a source of contaminant, a change to a *Point of Impingement* and all changes to information associated with a *Modification* to the *Facility* that satisfies Condition 2.
25. "*Minister*" means the Minister of the Environment and Climate Change or such other member of the Executive Council as may be assigned the administration of the *EPA* under the Executive Council Act.
26. "*Ministry*" means the ministry of the *Minister*.
27. "*Ministry Point of Impingement Limit*" means the applicable Standard set out in Schedule 2 or 3 of *O. Reg. 419/05* or a limit set out in the *Ministry* publication titled "Summary of Standards and Guidelines to support Ontario Regulation 419/05: Air Pollution - Local Air Quality (including Schedule 6 of *O. Reg. 419/05* on Upper Risk Thresholds", dated April 2012, as amended.
28. "*Modification*" means any construction, alteration, extension or replacement of any plant, structure, equipment, apparatus, mechanism or thing, or alteration of a process or rate of production at the *Facility* that may discharge or alter the rate or manner of discharge of a *Compound of Concern* to the air or discharge or alter noise or vibration emissions from the *Facility*.
29. "*Noise Control Measures*" means measures to reduce the noise emissions from the *Facility* and/or *Equipment* including, but not limited to, silencers, acoustic louvres, enclosures, absorptive treatment, plenums and barriers. It also means the noise control measures outlined in the *Acoustic Assessment Report*.
30. "*O. Reg. 419/05*" means Ontario Regulation 419/05, Air Pollution – Local Air Quality, as amended.

31. "*Original ESDM Report*" means the Emission Summary and Dispersion Modelling Report which was prepared in accordance with section 26 of *O. Reg. 419/05* and the *Procedure Document* by Watters Environmental Group Inc. and dated May 20, 2010 submitted in support of the application, and includes any changes to the report made up to the date of issuance of this *Approval*.

32. "*Point of Impingement*" has the same meaning as in section 2 of *O. Reg. 419/05*.

33. "*Point of Reception*" means Point of Reception as defined by *Publication NPC-205* and/or *Publication NPC-232*, as applicable.

34. "*Procedure Document*" means *Ministry* guidance document titled "Procedure for Preparing an Emission Summary and Dispersion Modelling Report" dated March 2009, as amended.

35. "*Processes with Significant Environmental Aspects*" means the *Equipment* which, during regular operation, would discharge one or more contaminants into the air in an amount which is not considered as negligible in accordance with section 26 (1) 4 of *O. Reg. 419/05* and the *Procedure Document*.

36. "*Publication NPC-103*" means the *Ministry* Publication NPC-103 of the Model Municipal Noise Control By-Law, Final Report, August 1978, published by the *Ministry* as amended.

37. "*Publication NPC-205*" means the *Ministry* Publication NPC-205, "Sound Level Limits for Stationary Sources in Class 1 & 2 Areas (Urban)", October, 1995, as amended.

38. "*Publication NPC-207*" means the *Ministry* draft technical publication "Impulse Vibration in Residential Buildings", November 1983, supplementing the Model Municipal Noise Control By-Law, Final Report, published by the *Ministry*, August 1978, as amended.

39. "*Publication NPC-232*" means the *Ministry* Publication NPC-232, "Sound Level Limits for Stationary Sources in Class 3 Areas (Rural)", October, 1995, as amended.

40. "*Publication NPC-233*" means the *Ministry* Publication NPC-233, "Information to be Submitted for Approval of Stationary Sources of Sound", October, 1995, as amended.

41. "*Schedules*" means the following schedules attached to this *Approval* and forming part of this *Approval* namely:

Schedule A - Supporting Documentation

42. "*Toxicologist*" means a qualified professional currently active in the field of risk assessment and toxicology that has a combination of formal university education, training and experience necessary to assess contaminants.

43. "*Written Summary Form*" means the electronic questionnaire form, available on the *Ministry* website, and supporting documentation, that documents the activities undertaken at the *Facility* in the previous calendar year.

You are hereby notified that this environmental compliance approval is issued to you subject to the terms and conditions outlined below:

TERMS AND CONDITIONS

1. GENERAL

1.1 Except as otherwise provided by this *Approval*, the *Facility* shall be designed, developed, built, operated and maintained in accordance with the terms and conditions of this *Approval* and in accordance with the following *Schedules* attached hereto:

2. LIMITED OPERATIONAL FLEXIBILITY

2.1 Pursuant to section 20.6 (1) of the *EPA* and subject to Conditions 2.2 and 2.3 of this *Approval*, future construction, alterations, extensions or replacements are approved in this *Approval* if the future construction, alterations, extensions or replacements are *Modifications* to the *Facility* that:

(a) are within the scope of the operations of the *Facility* as described in the *Description Section* of this *Approval*;

(b) do not result in an increase of the *Facility Production Limit* above the level specified in the *Description Section* of this *Approval*; and

(c) result in compliance with the performance limits as specified in Condition 4.

2.2 Condition 2.1 does not apply to,

(a) the addition of any new *Equipment with Specific Operational Limits* or to the *Modification* of any existing *Equipment with Specific Operational Limits* at the *Facility*; or

(b) *Modifications* to the *Facility* that would be subject to the *Environmental Assessment Act*.

2.3 Condition 2.1 of this *Approval* shall expire on February 1, 2020, unless this *Approval* is revoked prior to the expiry date. The *Company* may apply for renewal of Condition 2.1 of this *Approval* by including an *ESDM Report* and an *Acoustic Assessment Report* that describes the *Facility* as of the date of the renewal application.

3. REQUIREMENT TO REQUEST AN ACCEPTABLE POINT OF IMPINGEMENT CONCENTRATION

3.1 Prior to making a *Modification* to the *Facility* that satisfies Condition 2.1 (a) and (b), the *Company* shall prepare a proposed update to the *ESDM Report* to reflect the proposed *Modification*.

3.2 The *Company* shall request approval of an *Acceptable Point of Impingement Concentration* for a *Compound of Concern* if the *Compound of Concern* does not have a *Ministry Point of Impingement Limit* and a proposed update to an *ESDM Report* indicates that one of the following changes with respect to the concentration of the *Compound of Concern* may occur:

(a) The *Compound of Concern* was not a *Compound of Concern* in the previous version of the *ESDM Report* and

(i) the concentration of the *Compound of Concern* is higher than the *Jurisdictional Screening Level* for the contaminant; or

(ii) there is no *Jurisdictional Screening Level* for the contaminant .

(b) The concentration of the *Compound of Concern* in the updated *ESDM Report* is higher than:

(i) the most recent *Acceptable Point of Impingement Concentration*, and

(ii) the *Jurisdictional Screening Level* if a *Jurisdictional Screening Level* exists.

3.3 The request required by Condition 3.2 shall propose a concentration for the *Compound of Concern* and shall contain an assessment, performed by a *Toxicologist*, of the likelihood of the proposed concentration causing an adverse effect at *Points of Impingement*.

3.4 If the request required by Condition 3.2 is a result of a proposed *Modification* described in Condition 3.1, the *Company* shall submit the request, in writing, to the *Director* at least 30 days prior to commencing to make the *Modification*. The *Director* shall provide written confirmation of receipt of this request to the *Company*.

3.5 If a request is required to be made under Condition 3.2 in respect of a proposed *Modification* described in Condition 3.1, the *Company* shall not make the *Modification* mentioned in Condition 3.1 unless the request is approved in writing by the *Director*.

3.6 If the *Director* notifies the *Company* in writing that the *Director* does not approve the request, the *Company* shall,

(a) revise and resubmit the request; or

(b) notify the *Director* that it will not be making the *Modification*.

3.7 The re-submission mentioned in Condition 3.6 shall be deemed a new submission under Condition 3.2.

3.8 If the *Director* approves the request, the *Company* shall update the *ESDM Report* to reflect the *Modification*.

3.9 Condition 3 does not apply if Condition 2.1 has expired.

4. PERFORMANCE LIMITS

4.1. Subject to Condition 4.2, the *Company* shall not discharge or cause or permit the discharge of a *Compound of Concern* into the air if,

(a) the *Compound of Concern* has a *Ministry Point of Impingement Limit* and the discharge results in the concentration at a *Point of Impingement* exceeding the *Ministry Point of Impingement Limit*; or

(b) the *Compound of Concern* does not have a *Ministry Point of Impingement Limit* and the discharge results in the concentration at a *Point of Impingement* exceeding the higher of,

(i) if an *Acceptable Point of Impingement Concentration* exists the most recent *Acceptable Point of Impingement Concentration*, and

(ii) the *Jurisdictional Screening Level* if a *Jurisdictional Screening Level* exists.

4.2 Condition 4.1 does not apply if the *Ministry Point of Impingement Limit* has a 10-minute averaging period and no ambient monitor indicates an exceedance at a *Point of Impingement* where human activities regularly occur at a time when those activities regularly occur.

4.3 The *Company* shall:

(a) implement by not later than three (3) months after the date of this *Approval*, the *Noise Control Measures* outlined in the *Acoustic Assessment Report*;

(b) ensure, subsequent to the implementation of the proposed *Noise Control Measures* that the noise emissions from the *Facility* comply with the limits set in *Ministry Publication NPC-205*; and

(c) ensure that the *Noise Control Measures* are properly maintained and continue to provide the acoustical performance outlined in the *Acoustic Assessment Report*.

4.4 The *Company* shall, at all times, ensure that the vibration emissions from the *Facility* comply with the limits set out in *Ministry Publication NPC-207*.

4.5 The *Company* shall operate any *Equipment with Specific Operational Limits* approved by this

Approval in accordance with the *Original ESDM Report*.

5. DOCUMENTATION REQUIREMENTS

5.1. The *Company* shall maintain an up-to-date *Log*.

5.2. No later than June 30 in each year, the *Company* shall update the *Acoustic Assessment Report* and shall update the *ESDM Report* in accordance with section 26 of *O. Reg. 419/05* so that the information in the reports is accurate as of December 31 in the previous year.

5.3. The *Company* shall make the *Emission Summary Table* (see section 27 of *O. Reg. 419/05*) and *Acoustic Assessment Summary Table* available for examination by any person, without charge, by posting it on the Internet or by making it available during regular business hours at the *Facility*.

5.4 The *Company* shall, within three (3) months after the expiry of Condition 2.1 of this *Approval*, update the *ESDM Report* and the *Acoustic Assessment Report* such that the information in the reports is accurate as of the date that Condition 2.1 of this *Approval* expired.

5.5. Conditions 5.1 and 5.2 do not apply if Condition 2.1 has expired.

6. REPORTING REQUIREMENTS

6.1 Subject to Condition 6.2, the *Company* shall provide the *Director* no later than August 31 of each year, a *Written Summary Form* to be submitted through the *Ministry's* website that shall include the following:

(a) a declaration of whether the *Facility* was in compliance with section 9 of the *EPA, O. Reg. 419/05* and the conditions of this *Approval*;

(b) a summary of each *Modification* satisfying Condition 2.1 (a) and (b) that took place in the previous calendar year that resulted in a change in the previously calculated concentration at a *Point of Impingement* for any *Compound of Concern* or resulted in a change in the sound levels reported in the *Acoustic Assessment Summary Table* at any *Point of Reception*.

6.2 Condition 6.1 does not apply if Condition 2.1 has expired.

7. OPERATION AND MAINTENANCE

7.1 The *Company* shall prepare and implement, not later than three (3) months from the date of this *Approval*, operating procedures and maintenance programs for all *Processes with Significant Environmental Aspects*, which shall specify as a minimum:

(a) frequency of inspections and scheduled preventative maintenance;

(b) procedures to prevent upset conditions;

(c) procedures to minimize all fugitive emissions;

(d) procedures to prevent and/or minimize odorous emissions;

(e) procedures to prevent and/or minimize noise emissions; and

(f) procedures for record keeping activities relating to the operation and maintenance programs.

7.2 The *Company* shall ensure that all *Processes with Significant Environmental Aspects* are operated and maintained in accordance with this *Approval*, the operating procedures and maintenance programs.

8. COMPLAINTS RECORDING AND REPORTING

8.1 If at any time, the *Company* receives an environmental complaint from the public regarding the operation of the *Equipment* approved by this *Approval*, the *Company* shall take the following steps:

- (a) Record and number each complaint, either electronically or in a log book. The record shall include the following information: the time and date of the complaint and incident to which the complaint relates, the nature of the complaint, wind direction at the time and date of the incident to which the complaint relates and, if known, the address of the complainant.
- (b) Notify the *District Manager* of the complaint within two (2) business days after the complaint is received, or in a manner acceptable to the *District Manager*.
- (c) Initiate appropriate steps to determine all possible causes of the complaint, and take the necessary actions to appropriately deal with the cause of the subject matter of the complaint.
- (d) Complete and retain on-site a report written within one (1) week of the complaint date. The report shall list the actions taken to appropriately deal with the cause of the complaint and set out steps to be taken to avoid the recurrence of similar incidents.

9. RECORD KEEPING REQUIREMENTS

9.1 Any information requested by any employee in or agent of the *Ministry* concerning the *Facility* and its operation under this *Approval*, including, but not limited to, any records required to be kept by this *Approval*, shall be provided to the employee in or agent of the *Ministry*, upon request, in a timely manner.

9.2 Unless otherwise specified in this *Approval*, the *Company* shall retain, for a minimum of five (5) years from the date of their creation all reports, records and information described in this *Approval*, including,

- (a) a copy of the *Original ESDM Report* and each updated version;
- (b) a copy of each version of the *Acoustic Assessment Report*;
- (c) supporting information used in the emission rate calculations performed in the *ESDM Reports* and *Acoustic Assessment Reports*;
- (d) the records in the *Log*;
- (e) copies of each *Written Summary Form* provided to the *Ministry* under Condition 6.1 of this *Approval*;
- (f) records of maintenance, repair and inspection of *Equipment* related to all *Processes with Significant Environmental Aspects*; and
- (g) all records related to environmental complaints made by the public as required by Condition 8 of this *Approval*.

10. REVOCATION OF PREVIOUS APPROVALS

This *Approval* replaces and revokes all Certificates of Approval (Air) issued under section 9 EPA and Environmental Compliance Approvals issued under Part II.1 EPA to the *Facility* in regards to the activities mentioned in subsection 9(1) of the EPA and dated prior to the date of this *Approval*.

11. ACOUSTIC AUDIT

11.1 The *Company* shall carry out *Acoustic Audit* measurements on the actual noise emissions due to the operation of the *Facility*. The *Company*:

- (a) shall carry out *Acoustic Audit* measurements in accordance with the procedures in *Publication NPC-103*;

(b) shall submit an *Acoustic Audit Report* on the results of the *Acoustic Audit*, prepared by an *Independent Acoustical Consultant*, in accordance with the requirements of *Publication NPC-233*, to the *District Manager* and the *Director*, not later than six (6) months after the date of this *Approval*.

11.2 The *Director*:

(a) may not accept the results of the *Acoustic Audit* if the requirements of *Publication NPC-233* were not followed;

(b) may require the *Company* to repeat the *Acoustic Audit* if the results of the *Acoustic Audit* are found unacceptable to the *Director*.

SCHEDULE A

Supporting Documentation

(a) Environmental Compliance Approval Application, dated May 20, 2010, signed by Gerald Paranczuk and submitted by the *Company*;

(b) Emission Summary and Dispersion Modelling Report, prepared by Watters Environmental Group Inc. and dated May 20, 2010;

(c) *Acoustic Assessment Report*, prepared by J.E. Coulter Associates Limited, dated September 8, 2011 and signed by John Coulter, P.Eng.;

(d) Addendum to an Approval of Air letters, prepared by Watters Environmental Group Inc., dated May 7, 2012 and October 30, 2013;

(e) Addendum to an Application for an Environmental Compliance Approval (Air) letter, prepared by Watters Environmental Group Inc. and dated November 24, 2015 and

(f) Answers to MOECC Questions letter, prepared by Watters Environmental Group Inc. and dated January 8, 2016.

The reasons for the imposition of these terms and conditions are as follows:

GENERAL

1. Condition No. 1 is included to require the *Approval* holder to build, operate and maintain the *Facility* in accordance with the Supporting Documentation in Schedule A considered by the *Director* in issuing this *Approval*.

LIMITED OPERATIONAL FLEXIBILITY, REQUIREMENT TO REQUEST AN ACCEPTABLE POINT OF IMPINGEMENT CONCENTRATION AND PERFORMANCE LIMITS

2. Conditions No. 2, 3 and 4 are included to limit and define the *Modifications* permitted by this *Approval*, and to set out the circumstances in which the *Company* shall request approval of an *Acceptable Point of Impingement Concentration* prior to making *Modifications*. The holder of the *Approval* is approved for operational flexibility for the *Facility* that is consistent with the description of the operations included with the application up to the *Facility Production Limit*. In return for the operational flexibility, the *Approval* places performance based limits that cannot be exceeded under the terms of this *Approval*. *Approval* holders will still have to obtain other relevant approvals required to operate the *Facility*, including requirements under other environmental legislation such as the *Environmental Assessment Act*.

DOCUMENTATION REQUIREMENTS

3. Condition No. 5 is included to require the *Company* to maintain ongoing documentation that demonstrates compliance with the *Performance Limits* of this *Approval* and allows the *Ministry* to monitor on-going compliance with these *Performance Limits*. The *Company* is required to have an up to date *ESDM Report* and *Acoustic Assessment Report* that describe the *Facility* at all times and make the *Emission Summary Table* and *Acoustic Assessment Summary Table* from these reports available to the public on an ongoing basis in order to maintain public communication with regard to the emissions from the *Facility*.

REPORTING REQUIREMENTS

4. Condition No. 6 is included to require the *Company* to provide a yearly *Written Summary Form* to the *Ministry*, to assist the *Ministry* with the review of the site's compliance with the *EPA*, the regulations and this *Approval*.

OPERATION AND MAINTENANCE

5. Condition No. 7 is included to require the *Company* to properly operate and maintain the *Processes with Significant Environmental Aspects* to minimize the impact to the environment from these processes.

COMPLAINTS RECORDING AND REPORTING PROCEDURE

6. Condition No. 8 is included to require the *Company* to respond to any environmental complaints regarding the operation of the *Equipment*, according to a procedure that includes methods for preventing recurrence of similar incidents and a requirement to prepare and retain a written report.

RECORD KEEPING REQUIREMENTS

7. Condition No. 9 is included to require the *Company* to retain all documentation related to this *Approval* and provide access to employees in or agents of the *Ministry*, upon request, so that the *Ministry* can determine if a more detailed review of compliance with the *Performance Limits* is necessary.

REVOCATION OF PREVIOUS APPROVALS

8. Condition No. 10 is included to identify that this *Approval* replaces all Section 9 Certificate(s) of Approval and Part II.1 Approvals in regards to the activities mentioned in subsection 9(1) of the *EPA* and dated prior to the date of this *Approval*.

ACOUSTIC AUDIT

9. Condition No. 11 is included to require the *Company* to gather accurate information and submit an *Acoustic Audit Report* in accordance with procedures set in the *Ministry's* noise guidelines, so that the environmental impact and subsequent compliance with this *Approval* can be verified.

In accordance with Section 139 of the Environmental Protection Act, you may by written Notice served upon me, the Environmental Review Tribunal and in accordance with Section 47 of the Environmental Bill of Rights, 1993, S.O. 1993, c. 28 (Environmental Bill of Rights), the Environmental Commissioner, within 15 days after receipt of this Notice, require a hearing by the Tribunal. The Environmental Commissioner will place notice of your appeal on the Environmental Registry. Section 142 of the Environmental Protection Act provides that the Notice requiring the hearing shall state:

1. The portions of the environmental compliance approval or each term or condition in the environmental compliance approval in respect of which the hearing is required, and;
2. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

The Notice should also include:

3. The name of the appellant;
4. The address of the appellant;
5. The environmental compliance approval number;
6. The date of the environmental compliance approval;
7. The name of the Director, and;
8. The municipality or municipalities within which the project is to be engaged in.

And the Notice should be signed and dated by the appellant.

This Notice must be served upon:

The Secretary* Environmental Review Tribunal 655 Bay Street, Suite 1500 Toronto, Ontario M5G 1E5	AND	The Environmental Commissioner 1075 Bay Street, Suite 605 Toronto, Ontario M5S 2B1	AND	The Director appointed for the purposes of Part II.1 of the Environmental Protection Act Ministry of the Environment and Climate Change 135 St. Clair Avenue West, 1st Floor Toronto, Ontario M4V 1P5
--	-----	---	-----	---

*** Further information on the Environmental Review Tribunal's requirements for an appeal can be obtained directly from the Tribunal at: Tel: (416) 212-6349, Fax: (416) 326-5370 or www.ert.gov.on.ca**

This instrument is subject to Section 38 of the Environmental Bill of Rights, 1993, that allows residents of Ontario to seek leave to appeal the decision on this instrument. Residents of Ontario may seek leave to appeal within 15 days from the date this decision is placed on the Environmental Registry. By accessing the Environmental Registry at www.ebr.gov.on.ca, you can determine when the leave to appeal period ends.

The above noted activity is approved under s.20.3 of Part II.1 of the Environmental Protection Act.

DATED AT TORONTO this 29th day of September,
2016

Ian Greason, P.Eng.
Director
appointed for the purposes of Part II.1 of
the *Environmental Protection Act*

SM/
c: District Manager, MOECC Halton-Peel
Fatema Tawawala, Watters Environmental Group Inc.



Making Sustainability Happen